

Housing and Property Chamber

First-tier Tribunal for Scotland



First-tier Tribunal for Scotland (Housing and Property Chamber) (“the tribunal”)

Certificate of completion of work under section 60 of the Housing (Scotland) Act 2006 (“the Act”) of the Private Rented Housing Committee issued under the First-tier Tribunal for Scotland Housing and Property Chamber (Procedure) Regulations 2016

Chamber Ref: PRHP/RP/14/0281

Title number: REN 12418

Property: 21 Craighurn Crescent, Houston, PA6 7NE (“the property”)

The Parties:-

Mrs Margaret Kirkton, 21 Craighurn Crescent, Houston, PA6 7NE (“the tenant”)

Ms Fiona Margaret Siddall, Dewlands, Crayshill Road, Crayshill, Billericay, Essex (“the landlord”)

Tribunal Members:

Simone Sweeney (Legal member) Colin Campbell (Housing member)

CERTIFICATE OF COMPLETION

The tribunal hereby certifies that the work required by the **Repairing Standard Enforcement Order** relative to the Property served on 20th May 2015 has been completed. Accordingly, the said Repairing Standard Enforcement Order relative to the property has been discharged.

Right of Appeal

A party to this application, aggrieved by the decision of the tribunal may seek permission to appeal from the First-tier Tribunal on a point of law only within 30 days of the date the decision was sent to them.

Effect of Section 63

Where such an appeal is made, the effect of the decision and of the order is suspended until the appeal is abandoned or finally determined, and where the appeal is abandoned or finally determined by confirming the decision, the decision and the order will be treated as having effect from the day on which the appeal is abandoned or so determined.

IN WITNESS WHEREOF these presents typewritten on this are signed by Simone Sweeney, legal member of the First Tier Tribunal, at Glasgow, on 27th day of January, Two Thousand and Seventeen, in the presence of the undernoted witness:

Simone Sweeney

Legal member.....

B Quinn

Witness..

Designation.....

Business address.. ATLANTIC QUAY, 45 ROBERTSON STREET, GLASGOW,
G2 8JB

AT GLASGOW, ON 27th JANUARY 2017, I SIMONE SWEENEY
SOLICITOR DO HEREBY CERTIFY THIS DOCUMENT AS A TRUE
COPY OF THE ORIGINAL.

Simone Sweeney

Housing and Property Chamber

First-tier Tribunal for Scotland



First-tier Tribunal for Scotland (Housing and Property Chamber) (“the tribunal”)

Statement of facts and reasons for a decision to grant certificate of completion of work under section 60 of the Housing (Scotland) Act 2006 (“the Act”) of the Private Rented Housing Committee issued under the First-tier Tribunal for Scotland Housing and Property Chamber (Procedure) Regulations 2016

Chamber Ref: PRHP/RP/14/0281

Property: 21 Craighurn Crescent, Houston, PA6 7NE (“the property”)

The Parties:-

Mrs Margaret Kirkton, 21 Craighurn Crescent, Houston, PA6 7NE (“the tenant”)

Ms Fiona Margaret Siddall, Dewlands, Crayshill Road, Crayshill, Billericay, Essex (“the landlord”)

Tribunal Members:

Simone Sweeney (Legal member) Colin Campbell (Housing member)

Decision

1. That a certificate of completion of works in terms of section 60 of the Act be issued.

Statement of facts and reasons

2. The tribunal issued a Repairing Standard Enforcement Order ("RSEO") on 20th May 2015. The terms of the RSEO were that the landlord was required to carry out such work as was necessary to ensure that the house meets the repairing standard and in particular the following specific areas:-

- i. *To replace or carry out such works to the external door and the entrance to the storage cupboard at the rear of the property to ensure that it is wind and water tight and that it is in a reasonable state of repair;*
- ii. *To have a full inspection and test of all electrical wiring and appliances at the property by a suitably qualified independent electrical engineer, with particular emphasis on the shower unit in the bathroom and the wiring emanating from the storage cupboard in the upper hallway to ensure that all electrical installations at the property are in a reasonable state of repair and in proper working order and for the engineer to report on his findings with regard to their state of repair and working order and for the landlord to produce a copy of that report to the committee;*
- iii. *For the landlord to instruct an independent suitably qualified Gas Safe registered engineer to carry out an inspection of the boiler and heating system, for him to report on his findings with regard to their state of repair and working order and to produce a copy of that report to the committee. Should it be reported that the boiler and system for heating water are not in a reasonable state of repair and in proper working order following that inspection, then the engineer should carry out any necessary repairs or, as appropriate, replacement any fittings to ensure that the boiler and heating system are in proper working order and meet the repairing standard. If either the boiler or system for heating the property are found not to be in a reasonable state of repair, the landlord should provide receipts or evidence of the works undertaken. The landlord should also produce an up to date gas safety certificate on the installation and supply of gas;*
- iv. *For the landlord to provide satisfactory provision for detecting fires and for giving warning in the event of fire or suspected fire.*

3. It having been identified that the landlord had failed to comply with the terms of the RSEO, the tribunal issued an order in terms of section 26 of the Act. Notice was also given to the local authority under section 26 (2) of the Act.

Reference is made to the relevant notice, to the terms of the order issued by the tribunal dated, 26th May 2016 and the attached statement of decision.

4. As at 26th May 2016 the repairs identified by Mr Buchan, surveyor, in his report of 14th March 2016 remained outstanding. These were:
 - i. *A satisfactory electrical installation condition report to be produced;*
 - ii. *No earth bonding wires were attached to the pipes of the new boiler;*
 - iii. *The pipes and boiler are located directly above an electrical socket creating a hazard and either the boiler or the electrical socket(s) be relocated or re-arranged in order to remove the hazard.*
5. The report of Mr Buchan, the subsequent failure to comply order and notice to the local authority were intimated to the landlord. The matter was reported to Police Scotland.
6. Despite consistent requests to produce a satisfactory electrical installation condition report ("EICR") showing that all necessary repairs as required by the RSEO had been completed, the landlord failed to do so until 28th December 2016.
7. The EICR produced by the landlord's representative, My Tyler, bore the number 055054. It was dated 10th November 2016 and referred to the property. The report noted that the general condition of the electrical installations at the property to be, "*satisfactory.*" It noted, also, that the extent of the electrical installation covered by the report to be, "*power and lights.*" The report was produced by A.M. Electrical. No remedial action was identified as being required at the property.
8. The tribunal formed the view that the content of the EICR of 10th November 2016 produced on 28th December 2016 was sufficient to satisfy the issues identified by Mr Buchan in his report of 14th March 2016. For this reason and in light of there being no further issues outstanding, the tribunal determined that the landlord had satisfied the terms of the RSEO of 20th May 2015 and that a certificate of compliance in terms of section 60 of the Act be issued.

Right of Appeal

9. A party to this application, aggrieved by the decision of the tribunal may seek permission to appeal from the First-tier Tribunal on a point of law only within 30 days of the date the decision was sent to them.

Effect of Section 63

10. Where such an appeal is made, the effect of the decision and of the order is suspended until the appeal is abandoned or finally determined, and where the appeal is abandoned or finally determined by confirming the decision, the decision and the order will be treated as having effect from the day on which the appeal is abandoned or so determined.

Simone Sweeney

.....legal member

AT GLASGOW ON 27th JANUARY 2017



ELECTRICAL INSTALLATION CONDITION REPORT

(REQUIREMENTS FOR ELECTRICAL INSTALLATIONS
— BS 7671 (IET WIRING REGULATIONS))

SELECT
MEMBERSHIP
NUMBER

This certificate is not valid if the
number is defaced or altered

EICR 055054

Copyright © The Electrical Contractors' Association of Scotland

SECTION A. DETAILS OF THE CLIENT / PERSON ORDERING THE REPORT

Name: AM ELECTRICAL
Address: 28 ALLANSON AVE

SECTION B. REASON FOR PRODUCING THIS REPORT

Reason: LET IN - PURPOSE
Date(s) on which inspection and testing was carried out: 10/11/2016

SECTION C. DETAILS OF THE INSTALLATION WHICH IS THE SUBJECT OF THIS REPORT

Occupier: TENANT
Address: 21 CRAIC BURN CRES HILTON, MC 9NE
Description of premises (Tick as appropriate): Domestic ☒ Commercial ☐ Industrial ☐ Other ☐
Estimated age of the wiring system: 25-30 years. Evidence of additions or alterations Yes ☐ No ☐ Not apparent ☒
If 'Yes' estimate age: years. Installation records available? (Regulation 621.1) Yes ☐ No ☐ Date of last inspection:

SECTION D. EXTENT AND LIMITATIONS OF INSPECTION AND TESTING

Extent of the electrical installation covered by this report: POWER & LIGHTS

Agreed limitations including the reasons (Regulation 634.2): NA

Agreed with (name): NA

Operational limitations including the reasons: NA

The inspection and testing detailed in this report and accompanying schedules have been carried out in accordance with BS 7671:2008 (IET Wiring Regulations), as amended to It should be noted that cables concealed within trunking and conduits, under floors, in roof spaces, and generally within the fabric of the building or underground have not been inspected unless specifically agreed between the client and inspector prior to the inspection. An inspection should be made within an accessible roof space housing other electrical equipment.

SECTION E. SUMMARY OF THE CONDITION OF THE INSTALLATION

General condition of the installation (in terms of electrical safety): SATISFACTORY

Overall assessment of the installation in terms of its suitability for continued use

SATISFACTORY ~~UNSATISFACTORY~~ (Delete as appropriate)

*An unsatisfactory assessment indicates that dangerous (code C1) and/or potentially dangerous (code C2) conditions have been identified.

SECTION F. RECOMMENDATIONS

Where the overall assessment of the suitability of the installation for continued use above is stated as UNSATISFACTORY, I/we recommend that any observations classified as 'Danger present' (code C1) or 'Potentially dangerous' (code C2) are acted upon as a matter of urgency. Investigation without delay is recommended for observations identified as 'Further investigation required' (code FI). Observations classified as 'Improvement recommended' (code C3) should be given due consideration. Subject to the necessary remedial action being taken, I/we recommend that the installation is further inspected and tested by 10/11/17 (date)

SECTION G. DECLARATION

I/We, being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by my/our signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the inspection and testing, hereby declare that the information in this report, including the observations and the attached schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent and limitations in Section D of this report.

Inspected and tested by:

Name (Capitals): R. DICKSON
Signature: [Signature]
For/on behalf of: R. DICKSON ELECTRICAL
Position: ELEC
Address: 3/1 146 ST. ANDREWS ROAD
Date: 10/11/2016

Report authorised for issue by:

Name (Capitals): AS INSP
Signature: [Signature]
For/on behalf of:
Position:
Address:
Date:

SECTION H. SCHEDULE(S)

..... schedule(s) of inspection and schedule(s) of test results are attached.

The attached schedule(s) are part of this document and this report is valid only when they are attached to it.

OUTCOMES	Acceptable condition	Unacceptable condition	State C1 or C2	Improvement recommended	State C3	Further investigation	FI	Not verified	NV	Limitation	LIM	Not applicable	N/A
ITEM No.	DESCRIPTION												OUTCOME Use codes above. Provide additional comment where appropriate. C1, C2, C3 and FI coded items to be recorded in Section 2 of the Condition Report
1.0	DISTRIBUTOR'S / SUPPLY INTAKE EQUIPMENT												
1.1	Condition of service cable												✓
1.2	Condition of service head												✓
1.3	Condition of distributor's earthing arrangement												✓
1.4	Condition of meter tails – Distributor/Consumer												✓
1.5	Condition of metering equipment												✓
1.6	Condition of isolator (where present)												N/A
2.0	PRESENCE OF ADEQUATE ARRANGEMENTS FOR OTHER SOURCES SUCH AS MICROGENERATORS (551.6; 551.7)												N/A
3.0	EARTHING / BONDING ARRANGEMENTS (411.3; Chapter 54)												
3.1	Presence and condition of distributor's earthing arrangement (542.1.2.1; 542.1.2.2)												✓
3.2	Presence and condition of earth electrode connection where applicable (542.1.2.3)												N/A
3.3	Provision of earthing / bonding labels at all appropriate locations (514.13.1)												✓
3.4	Confirmation of earthing conductor size (542.3; 543.1.1)												✓
3.5	Accessibility and condition of earthing conductor at main earthing terminal (MET) (543.3.2)												✓
3.6	Confirmation of main protective bonding conductor sizes (544.1)												✓
3.7	Condition and accessibility of main protective bonding conductor connections (543.3.2; 544.1.2)												✓
3.8	Accessibility and condition of other protective bonding connections (543.3.2)												✓
4.0	CONSUMER UNIT(S) / DISTRIBUTION BOARD(S)												
4.1	Adequacy of working space / accessibility to consumer unit / distribution board (132.12; 513.1)												✓
4.2	Security of fixing (134.1.1)												✓
4.3	Condition of enclosure(s) in terms of IP rating etc (416.2)												✓
4.4	Condition of enclosure(s) in terms of fire rating etc (421.1.201; 526.5)												✓
4.5	Enclosure not damaged/deteriorated so as to impair safety (621.2(iii))												✓
4.6	Presence of main linked switch (as required by 537.1.4)												✓
4.7	Operation of main switch (functional check) (612.13.2)												✓
4.8	Manual operation of circuit-breakers and RCDs to prove disconnection (612.13.2)												✓
4.9	Correct identification of circuit details and protective devices (514.8.1; 514.9.1)												✓
4.10	Presence of RCD quarterly test notice at or near consumer unit / distribution board (514.12.2)												✓
4.11	Presence of non-standard (mixed) cable colour warning notice at or near consumer unit / distribution board (514.14)												✓
4.12	Presence of alternative supply warning notice at or near consumer unit / distribution board (514.15)												✓
4.13	Presence of other required labelling (please specify) (Section 514)												✓
4.14	Examination of protective device(s) and base(s), correct type and rating (no signs of unacceptable thermal damage, arcing or overheating) (421.1.3)												✓
4.15	Single-pole switching of protective devices in line conductors only (132.14.1; 530.3.2)												✓
4.16	Protection against mechanical damage where cables enter consumer unit / distribution board (522.8.1; 522.8.11)												✓
4.17	Protection against electromagnetic effects where cables enter consumer unit / distribution board / enclosures (521.5.1)												✓
4.18	RCD(s) provided for fault protection – includes RCBOs (411.4.9; 411.5.2; 531.2)												✓
4.19	RCD(s) provided for additional protection – includes RCBOs (411.3.3; 415.1)												✓
4.20	Confirmation of indication that SPD is functional (534.2.8)												✓
4.21	Confirmation that ALL conductor connections, including connections to busbars, are correctly located in terminals and are tight and secure (526.1)												✓
4.22	Adequate arrangements where a generating set operates as a switched alternative to the public supply (551.6)												N/A
4.23	Adequate arrangements where a generating set operates in parallel with the public supply (551.7)												N/A



CONDITION REPORT INSPECTION SCHEDULE (CONTINUED)

EICR 055054

OUTCOMES	Acceptable condition	✓	Unacceptable condition	State C1 or C2	Improvement recommended	State C3	Further investigation	FI	Not verified	IVV	Limitation	LIM	Not applicable	N/A
ITEM No.	DESCRIPTION										OUTCOME Use codes above. Provide evidence to confirm where appropriate. C1, C2, C3 and FI codes have to be recorded in Section K of the Condition Report.			
5.0	DISTRIBUTION / FINAL CIRCUITS													
5.1	Identification of conductors (514.3.1)										✓			
5.2	Cables correctly supported throughout their run (522.8.5)										✓			
5.3	Condition of insulation of live parts (416.1)										✓			
5.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking (521.10.1)										✓			
	a) To include the integrity of conduit and trunking systems (metallic and plastic)										✓			
5.5	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)										✓			
5.6	Coordination between conductors and overload protective devices (433.1, 533.2.1)										✓			
5.7	Adequacy of protective devices: type and rated current for fault protection (411.3)										✓			
5.8	Presence and adequacy of circuit protective conductors (411.3.1.1, 543.1)										✓			
5.9	Wiring system(s) appropriate for the type and nature of the installation and external influences (Section 522)										✓			
5.10	Concealed cables installed in prescribed zones (see Section D, Extent and limitations) (522.6.202)										N/A			
5.11	Cables concealed under floors, above ceilings or in walls/partitions: adequately protected against damage (see Section D, Extent and limitations) (522.6.201, 522.6.204)										✓			
5.12	Provision of additional protection by RCD not exceeding 30 mA										✓			
	a) for all socket-outlets of rating 20 A or less, unless an exception is permitted (411.3.3)										✓			
	b) for supply to mobile equipment not exceeding 32 A rating for use outdoors (411.3.3)										✓			
	c) for cables concealed in walls at a depth of less than 50 mm (522.6.202, 522.6.203)										✓			
	d) for cables concealed in walls/partitions containing metal parts regardless of depth (522.6.203)										✓			
5.13	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)										N/A			
5.14	Band II cables segregated / separated from Band I cables (528.1)										N/A			
5.15	Cables segregated / separated from communications cabling (528.2)										N/A			
5.16	Cables segregated / separated from non-electrical services (528.3)										N/A			
5.17	Termination of cables at enclosures - indicate extent of sampling in Section D of the report (Section 526)										✓			
	a) Connections soundly made and under no undue strain (526.6)										✓			
	b) No basic insulation of a conductor visible outside enclosure (526.8)										✓			
	c) Connections of live conductors adequately enclosed (526.5)										✓			
	d) Adequately connected at point of entry to enclosure (glands, bushes etc.) (522.8.5)										✓			
5.18	Condition of accessories including socket-outlets, switches and joint boxes (521.2 (iii))										✓			
5.19	Suitability of accessories for external influences (512.2)										✓			
5.20	Adequacy of working space / accessibility to equipment (132.12, 513.1)										✓			
5.21	Single-pole switching or protective devices in line conductors only (132.14.1, 530.3.2)										✓			
6.0	LOCATION(S) CONTAINING A BATH OR SHOWER													
6.1	Additional protection for all low voltage (LV) circuits by RCD not exceeding 30 mA (701.411.3.3)										✓			
6.2	Where used as a protective measure, requirements for SELV or PELV met (701.414.4.5)										N/A			
6.3	Shaver sockets comply with BS EN 61558-2-5 formerly BS 3535 (701.512.3)										N/A			
6.4	Presence of supplementary bonding conductors, unless not required by BS 7671:2008 (701.415.2)										✓			
6.5	Low voltage (e.g. 230 volt) socket-outlets sited at least 3 m from zone 1 (701.512.3)										N/A			
6.6	Suitability of equipment for external influences for installed location in terms of IP rating (701.512.2)										✓			
6.7	Suitability of accessories and control gear etc. for a particular zone (701.512.3)										✓			
6.8	Suitability of current-using equipment for particular position within the location (701.55)										✓			
7.0	OTHER PART 7 SPECIAL INSTALLATIONS OR LOCATIONS													
7.1	List all other special installations or locations present, if any. (Record separately the results of particular inspections applied.)										N/A			

Inspected by: NAME (CAPITALS) 2015

R. D. C. 2015

Signature

[Signature]

Date 10/11/16
Page 4 of 5

EICR 055054

CIRCUIT CHART AND SCHEDULE OF TEST RESULTS (18 CIRCUITS)

SELECT

Distribution Board Reference No. **214**
Location and Type **MAIN CUPS**

Details of circuits and/or installed equipment vulnerable to damage when testing

Z_s at DB **0.10** ☐
I_n at DB **2.16** ☐

Phase sequence confirmed (where appropriate) **NA**

Supply polarity confirmed ☒

CIRCUIT DETAILS

TEST RESULTS										TEST RESULTS													
No.	Circuit Description	No. of Circuits	Wiring Details			Overcurrent Device Breaking Capacity			Continuity				Insulation Resistance (Lowest values measured)			Po- larity	RCD Protection			Func- tional Testing	Remarks		
			Type	Size	Cable	Type	Amps	kA	R1+R2 or R2	Q	Ring Final Circuit			MC			I _n	Time (ms)					
											L-L	N-N	CPC/ CPC	L-L	L-E				Q			mA	100% T500mA
	SINKER	1	A	3	2.5	15	B	40	0.06						249	249	✓	0.16	30	21	4	✓	
	RADIANT SETS	6	A	3	2.5	15	B	16	0.09						249	249	✓	0.58	30	21	4	✓	
	CORNER	1	A	3	6	4	B	32	0.07						249	249	✓	0.16	30	21	4	✓	
	RADIANT SETS	3	A	3	2.5	15	B	16	0.41						249	249	✓	0.51	30	21	4	✓	
	SPARE	1	A	3	2.5	15	B	16	0.53						249	249	✓	0.44	30	21	4	✓	
	WATER HEATER	1	A	3	2.5	15	B	16	0.53						249	249	✓	0.41	30	21	4	✓	
	SPARE	1	A	3	2.5	15	B	16	0.81						249	249	✓	0.43	30	21	4	✓	
	LIGHTING	7	A	3	1.5	1	B	6	0.33						249	249	✓	0.43	30	21	4	✓	
	OUTSIDE	2	A	3	1.5	1	B	6	0.51						249	249	✓	0.61	30	21	4	✓	
	SMOKE ALARM	3	A	3	1.5	1	B	6	0.51						249	249	✓	0.61	30	21	4	✓	

* Select 40Amps or 60Amps or 100Amps or 125Amps or 160Amps or 200Amps or 250Amps or 315Amps or 400Amps or 500Amps or 630Amps or 800Amps or 1000Amps or 1250Amps or 1600Amps or 2000Amps or 2500Amps or 3150Amps or 4000Amps or 5000Amps or 6300Amps or 8000Amps or 10000Amps or 12500Amps or 16000Amps or 20000Amps or 25000Amps or 31500Amps or 40000Amps or 50000Amps or 63000Amps or 80000Amps or 100000Amps or 125000Amps or 160000Amps or 200000Amps or 250000Amps or 315000Amps or 400000Amps or 500000Amps or 630000Amps or 800000Amps or 1000000Amps or 1250000Amps or 1600000Amps or 2000000Amps or 2500000Amps or 3150000Amps or 4000000Amps or 5000000Amps or 6300000Amps or 8000000Amps or 10000000Amps or 12500000Amps or 16000000Amps or 20000000Amps or 25000000Amps or 31500000Amps or 40000000Amps or 50000000Amps or 63000000Amps or 80000000Amps or 100000000Amps or 125000000Amps or 160000000Amps or 200000000Amps or 250000000Amps or 315000000Amps or 400000000Amps or 500000000Amps or 630000000Amps or 800000000Amps or 1000000000Amps or 1250000000Amps or 1600000000Amps or 2000000000Amps or 2500000000Amps or 3150000000Amps or 4000000000Amps or 5000000000Amps or 6300000000Amps or 8000000000Amps or 10000000000Amps or 12500000000Amps or 16000000000Amps or 20000000000Amps or 25000000000Amps or 31500000000Amps or 40000000000Amps or 50000000000Amps or 63000000000Amps or 80000000000Amps or 100000000000Amps or 125000000000Amps or 160000000000Amps or 200000000000Amps or 250000000000Amps or 315000000000Amps or 400000000000Amps or 500000000000Amps or 630000000000Amps or 800000000000Amps or 1000000000000Amps or 1250000000000Amps or 1600000000000Amps or 2000000000000Amps or 2500000000000Amps or 3150000000000Amps or 4000000000000Amps or 5000000000000Amps or 6300000000000Amps or 8000000000000Amps or 10000000000000Amps or 12500000000000Amps or 16000000000000Amps or 20000000000000Amps or 25000000000000Amps or 31500000000000Amps or 40000000000000Amps or 50000000000000Amps or 63000000000000Amps or 80000000000000Amps or 100000000000000Amps or 125000000000000Amps or 160000000000000Amps or 200000000000000Amps or 250000000000000Amps or 315000000000000Amps or 400000000000000Amps or 500000000000000Amps or 630000000000000Amps or 800000000000000Amps or 1000000000000000Amps or 1250000000000000Amps or 1600000000000000Amps or 2000000000000000Amps or 2500000000000000Amps or 3150000000000000Amps or 4000000000000000Amps or 5000000000000000Amps or 6300000000000000Amps or 8000000000000000Amps or 10000000000000000Amps or 12500000000000000Amps or 16000000000000000Amps or 20000000000000000Amps or 25000000000000000Amps or 31500000000000000Amps or 40000000000000000Amps or 50000000000000000Amps or 63000000000000000Amps or 80000000000000000Amps or 100000000000000000Amps or 125000000000000000Amps or 160000000000000000Amps or 200000000000000000Amps or 250000000000000000Amps or 315000000000000000Amps or 400000000000000000Amps or 500000000000000000Amps or 630000000000000000Amps or 800000000000000000Amps or 1000000000000000000Amps or 1250000000000000000Amps or 1600000000000000000Amps or 2000000000000000000Amps or 2500000000000000000Amps or 3150000000000000000Amps or 4000000000000000000Amps or 5000000000000000000Amps or 6300000000000000000Amps or 8000000000000000000Amps or 10000000000000000000Amps or 12500000000000000000Amps or 16000000000000000000Amps or 20000000000000000000Amps or 25000000000000000000Amps or 31500000000000000000Amps or 40000000000000000000Amps or 50000000000000000000Amps or 63000000000000000000Amps or 80000000000000000000Amps or 100000000000000000000Amps or 125000000000000000000Amps or 160000000000000000000Amps or 200000000000000000000Amps or 250000000000000000000Amps or 315000000000000000000Amps or 400000000000000000000Amps or 500000000000000000000Amps or 630000000000000000000Amps or 800000000000000000000Amps or 1000000000000000000000Amps or 1250000000000000000000Amps or 1600000000000000000000Amps or 2000000000000000000000Amps or 2500000000000000000000Amps or 3150000000000000000000Amps or 4000000000000000000000Amps or 5000000000000000000000Amps or 6300000000000000000000Amps or 8000000000000000000000Amps or 10000000000000000000000Amps or 12500000000000000000000Amps or 16000000000000000000000Amps or 20000000000000000000000Amps or 25000000000000000000000Amps or 31500000000000000000000Amps or 40000000000000000000000Amps or 50000000000000000000000Amps or 63000000000000000000000Amps or 80000000000000000000000Amps or 100000000000000000000000Amps or 125000000000000000000000Amps or 160000000000000000000000Amps or 200000000000000000000000Amps or 250000000000000000000000Amps or 315000000000000000000000Amps or 400000000000000000000000Amps or 500000000000000000000000Amps or 630000000000000000000000Amps or 800000000000000000000000Amps or 1000000000000000000000000Amps or 1250000000000000000000000Amps or 1600000000000000000000000Amps or 2000000000000000000000000Amps or 2500000000000000000000000Amps or 3150000000000000000000000Amps or 4000000000000000000000000Amps or 5000000000000000000000000Amps or 6300000000000000000000000Amps or 8000000000000000000000000Amps or 10000000000000000000000000Amps or 12500000000000000000000000Amps or 16000000000000000000000000Amps or 20000000000000000000000000Amps or 25000000000000000000000000Amps or 31500000000000000000000000Amps or 40000000000000000000000000Amps or 50000000000000000000000000Amps or 63000000000000000000000000Amps or 80000000000000000000000000Amps or 100000000000000000000000000Amps or 125000000000000000000000000Amps or 160000000000000000000000000Amps or 200000000000000000000000000Amps or 250000000000000000000000000Amps or 315000000000000000000000000Amps or 400000000000000000000000000Amps or 500000000000000000000000000Amps or 630000000000000000000000000Amps or 800000000000000000000000000Amps or 1000000000000000000000000000Amps or 1250000000000000000000000000Amps or 1600000000000000000000000000Amps or 2000000000000000000000000000Amps or 2500000000000000000000000000Amps or 3150000000000000000000000000Amps or 4000000000000000000000000000Amps or 5000000000000000000000000000Amps or 6300000000000000000000000000Amps or 8000000000000000000000000000Amps or 10000000000000000000000000000Amps or 12500000000000000000000000000Amps or 16000000000000000000000000000Amps or 20000000000000000000000000000Amps or 25000000000000000000000000000Amps or 31500000000000000000000000000Amps or 40000000000000000000000000000Amps or 50000000000000000000000000000Amps or 63000000000000000000000000000Amps or 80000000000000000000000000000Amps or 100000000000000000000000000000Amps or 125000000000000000000000000000Amps or 160000000000000000000000000000Amps or 200000000000000000000000000000Amps or 250000000000000000000000000000Amps or 315000000000000000000000000000Amps or 400000000000000000000000000000Amps or 500000000000000000000000000000Amps or 630000000000000000000000000000Amps or 800000000000000000000000000000Amps or 1000000000000000000000000000000Amps or 1250000000000000000000000000000Amps or 1600000000000000000000000000000Amps or 2000000000000000000000000000000Amps or 2500000000000000000000000000000Amps or 3150000000000000000000000000000Amps or 4000000000000000000000000000000Amps or 5000000000000000000000000000000Amps or 6300000000000000000000000000000Amps or 8000000000000000000000000000000Amps or 10000000000000000000000000000000Amps or 12500000000000000000000000000000Amps or 16000000000000000000000000000000Amps or 20000000000000000000000000000000Amps or 25000000000000000000000000000000Amps or 31500000000000000000000000000000Amps or 40000000000000000000000000000000Amps or 50000000000000000000000000000000Amps or 63000000000000000000000000000000Amps or 80000000000000000000000000000000Amps or 100000000000000000000000000000000Amps or 125000000000000000000000000000000Amps or 160000000000000000000000000000000Amps or 200000000000000000000000000000000Amps or 250000000000000000000000000000000Amps or 315000000000000000000000000000000Amps or 400000000000000000000000000000000Amps or 500000000000000000000000000000000Amps or 630000000000000000000000000000000Amps or 800000000000000000000000000000000Amps or 1000000000000000000000000000000000Amps or 1250000000000000000000000000000000Amps or 1600000000000000000000000000000000Amps or 2000000000000000000000000000000000Amps or 2500000000000000000000000000000000Amps or 3150000000000000000000000000000000Amps or 4000000000000000000000000000000000Amps or 5000000000000000000000000000000000Amps or 6300000000000000000000000000000000Amps or 8000000000000000000000000000000000Amps or 10000000000000000000000000000000000Amps or 12500000000000000000000000000000000Amps or 16000000000000000000000000000000000Amps or 20000000000000000000000000000000000Amps or 25000000000000000000000000000000000Amps or 31500000000000000000000000000000000Amps or 40000000000000000000000000000000000Amps or 50000000000000000000000000000000000Amps or 63000000000000000000000000000000000Amps or 80000000000000000000000000000000000Amps or 100000000000000000000000000000000000Amps or 125000000000000000000000000000000000Amps or 160000000000000000000000000000000000Amps or 200000000000000000000000000000000000Amps or 250000000000000000000000000000000000Amps or 315000000000000000000000000000000000Amps or 400000000000000000000000000000000000Amps or 500000000000000000000000000000000000Amps or 630000000000000000000000000000000000Amps or 800000000000000000000000000000000000Amps or 1000000000000000000000000000000000000Amps or 1250000000000000000000000000000000000Amps or 1600000000000000000000000000000000000Amps or 2000000000000000000000000000000000000Amps or 2500000000000000000000000000000000000Amps or 3150000000000000000000000000000000000Amps or 4000000000000000000000000000000000000Amps or 5000000000000000000000000000000000000Amps or 6300000000000000000000000000000000000Amps or 8000000000000000000000000000000000000Amps or 10000000000000000000000000000000000000Amps or 12500000000000000000000000000000000000Amps or 16000000000000000000000000000000000000Amps or 20000000000000000000000000000000000000Amps or 25000000000000000000000000000000000000Amps or 31500000000000000000000000000000000000Amps or 40000000000000000000000000000000000000Amps or 50000000000000000000000000000000000000Amps or 63000000000000000000000000000000000000Amps or 80000000000000000000000000000000000000Amps or 100000000000000000000000000000000000000Amps or 125000000000000000000000000000000000000Amps or 160000000000000000000000000000000000000Amps or 200000000000000000000000000000000000000Amps or 250000000000000000000000000000000000000Amps or 315000000000000000000000000000000000000Amps or 400000000000000000000000000000000000000Amps or 500000000000000000000000000000000000000Amps or 630000000000000000000000000000000000000Amps or 800000000000000000000000000000000000000Amps or 1000000000000000000000000000000000000000Amps or 1250000000000000000000000000000000000000Amps or 1600000000000000000000000000000000000000Amps or 2000000000000000000000000000000000000000Amps or 2500000000000000000000000000000000000000Amps or 3150000000000000000000000000000000000000Amps or 4000000000000000000000000000000000000000Amps or 5000000000000000000000000000000000000000Amps or 6300000000000000000000000000000000000000Amps or 800000000